



**ENVIRONMENTAL  
TESTING SERVICES LLC.**

## **Lead and Copper in Drinking Water Sampling**

### **Catholic Charities**

**594 N. 7th, St. Newark, NJ 07107. 2nd Floor**

**Inspection Company:  
Environmental Testing Services LLC.  
619 Wills Ave.  
Deptford, NJ 08096**

**Laboratory:  
Accurate Analytical, Inc.  
30105 Beverly Road  
Romulus, MI 48174**

**Lead in Drinking Water Sampling Date:  
December 1st, 2021**

**Licensed State Lead Inspector  
Risk Assessor  
Matthew Stefkovic (License # NJ 036151)**

December 1<sup>st</sup>, 2021

Catholic Charities  
594 N. 7th, St.  
Newark, NJ 07107. 2nd Floor

**Re: Lead and Copper in Drinking Water Sampling  
594 N. 7th, St. Newark, NJ 07107. 2nd Floor.**

Dear Client:

Environmental Testing Services, LLC. provided water testing for lead and copper on December 1st, 2021.

The purpose of this project was to sample the school's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test shows lead and copper amounts exceeding the EPA limit of 15 ug/L for lead and 1300 ug/L for Copper. The locations of each testing location were given to the inspector earlier as to where the use of each water source frequently used.

Samples were collected in 250 ml bottles. Samples were immediately transported to Accurate Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

Results of the sampling found that all of the water sources tested fell under the EPA limit of 15 ug/L for lead and 1300 ug/L for Copper.

Sample analysis results and the chain of custody are attached to this report. If you should have any questions, please feel free to contact us at (856) 432-4468

There were two inoperable water fountains in the hall way, therefore, samples were not collected from them.

Sincerely,



Matthew Stefkovic,  
Risk Assessor

## Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to Accurate Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

*The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." For water, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*

The results from the lab are given in ug/L.

**Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.**

Wipe Sample	Sampling Location Description	Laboratory Results <u>LEAD</u> (ug/L)	Laboratory Results <u>COPPER</u> (ug/L)
1	GIRLS SINK 2	passed	passed
2	GIRLS SINK 4	passed	passed
3	BOYS SINK 1	passed	passed
4	BOYS SINK 2	passed	passed
5	STAFF ROOM SINK	passed	passed
1. The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L. 2. The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L.			

# LAB Results



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-623-8161; Fax: 734-623-8431

## Certificate of Analysis: Lead in Drinking Water by EPA Method 200.5

<b>Client:</b> Environmental Testing Services 619 Mills Ave Deptford, NJ 08056 <b>Attn:</b> Mike Stefkovic <b>Email:</b> lead@eis-enviro.com <b>Phone:</b> 215-432-4468 <b>Fax:</b>	<b>AAT Project:</b> 739988 <b>Sampling Date:</b> 12/01/2021 <b>Date Received:</b> 12/02/2021 <b>Date Analyzed:</b> 12/02/2021 <b>Date Reported:</b> 12/3/2021 4:00:05AM <b>WS&amp;N:</b>
<b>Client Project:</b> CATHOLIC CHARITIES <b>Collected By:</b>	
<b>Project Location:</b> 594 NORTH 7TH ST NEWARK NJ 07107	

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
6963395	1	GIRLS SINK 2 250 ML	PBCU	0	1.0	1.0	Below
6963390	2	GIRLS SINK 4 250 ML	PBCU	0	1.3	1.0	Below
6963391	3	BOYS SINK 1 250 ML	PBCU	0	3.7	1.0	Below
6963392	4	BOYS SINK 2 250 ML	PBCU	0	1.6	1.0	Below
6963393	5	STAFF ROOM SINK 250 ML	PBCU	0	1.6	1.0	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is 1 µg/L (ppb) and for Cu is 1.0 µg/L (ppb). For this analysis results (2) significant figures. AAT utilizes EPA 82301 (for Method and Lead) (2) are acceptable unless otherwise stated. EPA Regulatory Limits: 15 µg/L for Pb and 1.302 µg/L for Cu. The laboratory operates in accordance with NELAP guidelines and holds accreditation under the NY State DGH E-LAP program. These results are submitted pursuant to AAT's LLC current terms and conditions of sale (including the company's standard warranty and limitation of liability provisions). Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All quality control requirements for the samples this report reflects have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT's LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

**Certificate of Analysis: Copper in Drinking Water by EPA Method 200.5**

Client : Environmental Testing Services 513 Wills Ave Deptford, NJ 08096	AAT Project : 739968 Sampling Date : 12/01/2021 Data Received : 12/02/2021 Date Analyzed : 12/02/2021 Date Reported : 12/02/2021 4:00:00AM
Attn : Mike Stefkovic      Email : <a href="mailto:lead@ets-enviro.com">lead@ets-enviro.com</a>	
Phone : 215-432-4465      Fax :	
Client Project : CATHOLIC CHARITIES      Collected By : WSNH	
Project Location : 594 NORTH 7TH ST NEWARK NJ 07107	

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
6963389	1	GIRLS SINK 2 250 ML	PBCU	0	100.6	Below
6963390	2	GIRLS SINK 4 250 ML	PBCU	0	103.6	Below
6963391	3	BOYS SINK 1 250 ML	PBCU	0	365.7	Below
6963392	4	BOYS SINK 2 250 ML	PBCU	0	120.7	Below
6963393	5	STAFF ROOM SINK 250 ML	PBCU	0	130.0	Below

Analyst Signature

Joseph Kerwabikise

ND - Not Detected, NA - Not Available, RL - Reporting Limit, The Analytical Reporting Limit for Pb is 1 µg/L (ppb) and for Cu is 1.3 µg/L (ppb).  
 For this analysis we used (1) certified reference AAT copper BCP BCR. The method and batch QC are acceptable unless otherwise noted.  
 EPA Regulatory Limits: 15 µg/L for Pb and 1.300 µg/L for Cu.  
 The laboratory operates in accordance with ISO/IEC 17025 and holds accreditation under the NY State DOH (ELAP) program. These results are submitted pursuant to AAT LLC's terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.  
 All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT LLC. Samples are stored for 15 days following report date.



NY State DOH FLAP Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 12/03/2021

AAT Project: 739968

# CHAIN OF CUSTODY

**CONTACT INFORMATION**

**SUBMITTING COMPANY**  
 Environmental Testing Services Inc.  
 311 9th Ave. Deptford NJ 08048



38166 BEVERLY RD  
 ROMULUS MI 48174  
 (734) 699-1483  
 FAX: (734) 699-8407

Website: www.aai.com  
 Email: customer.support@aaicom.com

Office: 866-224-2114

Fax:

Email 1:

Email 2:

866-224-2114  
 866-224-2114

PROJECT NUMBER: 594 PROJECT ADDRESS: 1211 2020 SAMPLING DATE: 12/1/2020

PERSON COLLECTING THE SAMPLES: Walter J. Smith, MS, C. H. S. T.

REGISTERED ANALYSIS: Drinking Water

WSSN: \_\_\_\_\_

LEAD:  LEAD:   
 COPPER:  COPPER:   
 BOTH:  BOTH:

TURNAROUND TIME (please check one)  
 24 Hour  48 Hour   
 72 Hour  3 Days   
 \*Pro "AT" is indicated default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE OR PURPOSE	TIME	VOLUME	CLIENT COMMENTS
616377	1	COIN'S SINK #2	P/CO		25.0 ML	SAMPLES SHIPPED
	2	COIN'S SINK #4	P/CO		25.0 ML	SAMPLES ACQUIRED Y N
	3	COIN'S SINK #1	P/CO		25.0 ML	NY STATE SAMPLES
	4	COIN'S SINK #2	P/CO		25.0 ML	CHECK HERE
	5	COIN'S SINK #3	P/CO		25.0 ML	SAMPLE CONDITION
						SEALS INTACT Y N
						CONTAINER LABELED Y N
						RECV'D & ACCEPTED Y N
						SAMPLES ACQUIRED Y N
						LAB REMARKS

LAB PROJECT NUMBER: 2009  
759988

SAMPLES RELINQUISHED BY: [Signature] DATE: \_\_\_\_\_ TIME: \_\_\_\_\_


SAMPLES RECEIVED BY: [Signature] DATE: \_\_\_\_\_ TIME: \_\_\_\_\_

AM PM AM PM

By returning samples to AAI, the client agrees to AAI terms and conditions. AAI is not responsible for shipping delays.

Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

LEAD CERTIFICATIONS  
ETS LLC.  
STATE OF NJ



## Certificate of Completion

awarded to

**Matthew Stefkovic**

for successfully completing the prescribed course of study in

**New Jersey Lead Inspector/Risk Assessor,  
Housing and Public Buildings**

in accordance with EPA and HUD Guidelines

presented by

**ACCESS TRAINING SERVICES, INC.**  
7921 River Road, Pennington, New Jersey 08118  
(856) 645-3449

8/31-9/4/28  
Course Dates

9/4/28  
Exam Date

9/4/22  
Expiration Date

N/A  
Social Security Number

ACC-8928-17-007  
Certificate Number

[Signature]  
Mark E. Schlager  
Training Director

